

NOTICE OF DRINKING WATER TOTAL HALOACETIC ACIDS VIOLATION

The Texas Commission on Environmental Quality (TCEQ) has notified the City of Groesbeck TX1470002 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for haloacetic acids (group of five). The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for haloacetic acids (group of five) to be 0.060 milligrams per liter (mg/L) based on locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for haloacetic acids (group of five) indicates a compliance value in quarter three 2020 of 0.065 mg/L for DBP2-02 – 1023 McClintic Dr., Groesbeck, TX.

Haloacetic acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing HAA5 in excess of the MCL over many years may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue: We are changing some of our treatment techniques at the water treatment plant and increasing the amount of monthly water line flushing to lower the HAA5 levels in the system.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Keith Tilley at 254-729-3293.

Posted on: August 21, 2020 / Delivered on: August 31, 2020