

Public Notice for March 2017

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck, PWS ID: TX1470002, failed to meet the minimum treatment technique requirements for the month of March 2017. Specifically, in March 2017, our water system had failure to provide Cryptosporidium treatment.

However, there have been no tests that were positive for Cryptosporidium anywhere in our system. This violation continues because of a lack of paperwork that the state has to have in their files. We continue to wait on them to send us the information needed to enter onto the monthly report forms. This is an EPA requirement. We will notify all customers by mail and on the City's website www.cityofgroesbeck.com once the compliance issues on the reporting forms are resolved.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Keith Tilley at 254-729-3293.

Posted/Delivered on: March 31, 2017

Public Notice for February 2017

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of February 2017. Specifically, in February 2017, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

However, there have been no tests that were positive for Cryptosporidium anywhere in our system. This violation continues because of a lack of paperwork that the state has to have in their files. We continue to wait on them to send us the information needed to enter onto the monthly report forms. This is an EPA requirement. We will notify all customers by mail and on the City's website www.cityofgroesbeck.com once the compliance issues on the reporting forms are resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for January 2017

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of January 2017. Specifically, in January 2017, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

However, there have been no tests that were positive for Cryptosporidium anywhere in our system. This violation continues because of a lack of paperwork that the state has to have in their files. We continue to wait on them to send us the information needed to enter onto the monthly report forms. This is an EPA requirement. We will notify all customers by mail and on the City's website www.cityofgroesbeck.com once the compliance issues on the reporting forms are resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for December 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of December 2016. Specifically, in December 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

However, there have been no tests that were positive for Cryptosporidium anywhere in our system. This violation continues because of a lack of paperwork that the state has to have in their files. We continue to wait on them to send us the information needed to enter onto the monthly report forms. This is an EPA requirement. We will notify all customers by mail and on the City's website www.cityofgroesbeck.com once the compliance issues on the reporting forms are resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for November 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of November 2016. Specifically, in November 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

However, there have been no tests that were positive for Cryptosporidium anywhere in our system. This violation continues because of a lack of paperwork that the state has to have in their files. We continue to wait on them to send us the information needed to enter onto the monthly report forms. This is an EPA requirement. We will notify all customers by mail and on the City's website www.cityofgroesbeck.com once the compliance issues on the reporting forms are resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for October 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of October 2016. Specifically, in October 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

However, there have been no tests that were positive for Cryptosporidium anywhere in our system. This violation continues because of a lack of paperwork that the state has to have in their files. We continue to wait on them to send us the proper report forms. We will notify all customers by mail and on the City's website www.cityofgroesbeck.com once the report forms have been sent to us and all compliance issues are resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for August 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of August 2016. Specifically, in August 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

However, there have been no tests that were positive for Cryptosporidium anywhere in our system. This is only a paperwork violation because we did not have a computer that would give us the information to put on the TCEQ monthly reports. We will notify all customers by mail and on the City's website www.cityofgroesbeck.com once the computer installation is finished and all compliance issues are resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for July 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of July 2016. Specifically, in July 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

This does not mean that there was anything wrong with the water at the plant during this month nor does it mean there is something wrong with it now. All tests have been performed on our water to ensure that it is safe to drink and no positive samples have been indicated for Cryptosporidium in July 2016. We will continue operating by TCEQ rules until this issue is resolved by our city engineers or the TCEQ and customers will continue to be notified by mail and the city's website www.cityofgroesbeck.com. We will also notify all customers once the issue is resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for June 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of June 2016. Specifically, in June 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

This does not mean that there was anything wrong with the water at the plant during this month nor does it mean there is something wrong with it now. All tests have been performed on our water to ensure that it is safe to drink and no positive samples have been indicated for Cryptosporidium in June 2016. We will continue operating by TCEQ rules until this issue is resolved by our city engineers or the TCEQ and customers will continue to be notified by mail and the city's website www.cityofgroesbeck.com. We will also notify all customers once the issue is resolved.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for May, 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of May 2016. Specifically, in May 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

This does not mean that there was anything wrong with the water at the plant during this month nor does it mean there is something wrong with it now. All tests have been performed on our water to ensure that it is safe to drink and no positive samples have been indicated for Cryptosporidium in May 2016. The violation is only a problem with the monthly reporting paperwork because the TCEQ has not approved our UV system upgrade at this time. We will continue operating by TCEQ rules until this upgrade to our system has been approved which means customers will continue to be notified by mail and the city's website. We will also notify all customers once the TCEQ approves the UV system upgrade.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for April, 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the month of April 2016. Specifically, in April 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation.

This does not mean that there was anything wrong with the water at the plant during this month nor does it mean there is something wrong with it now. All tests have been performed on our water to ensure that it is safe to drink and no positive samples have been indicated for Cryptosporidium in April 2016. The violation is only a problem with the monthly reporting paperwork because the TCEQ has not approved our UV system upgrade at this time. We will continue operating by TCEQ rules until this upgrade to our system has been approved which means customers will continue to be notified by mail and the city's website. We will also notify all customers once the TCEQ approves the UV system upgrade.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).

Public Notice for January through March, 2016

Notice of Surface Water Treatment Technique Violation

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Groesbeck failed to meet the minimum treatment technique requirements for the months of January, February and March 2016. Specifically, in January 2016, our water system failed to meet the microbial treatment requirements for Cryptosporidium inactivation and for the months of February and March 2016, our water system failed to provide treatment for Cryptosporidium.

This does not mean that there was anything wrong with the water at the plant during these three months nor does it mean there is something wrong with it now. All tests have been performed on our water to ensure that it is safe to drink and no positive samples have been indicated for Cryptosporidium in any of the three months mentioned. The violation is only a problem with the monthly reporting paperwork because the TCEQ has not approved our UV system upgrade at this time. We will continue operating by TCEQ rules until this upgrade to our system has been approved which means customers will continue to be notified by mail and the city's website. We will also notify all customers once the TCEQ approves the UV system upgrade.

If you want more information about the nature and significance of this violation, you may contact Keith Tilley at 254-729-3293.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).