

**PUBLIC NOTICE MANDATORY LANGUAGE CODING**  
**Tier 2 violations/ Non-Acute**

**Mandatory Language for Surface Water Treatment Technique Violation**

**SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]**

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

The **City of Groesbeck**, PWS ID TX 1470002, failed to meet the minimum treatment technique requirements for the month of **February and March 2025**.

Specifically, our water system had failed to achieve at least 99% (2-log) removal of Cryptosporidium.

The violation occurred due to the failure of UV System electronics.

No positive samples of Cryptosporidium have been detected in the drinking water as of 3/26/2025.

**This is an updated Public Notice.**

**The City of Groesbeck has taken the following corrective actions to prevent a recurrence of the violations: The City of Groesbeck has engaged in a contract with Trojan Technologies to do re-programming and repair of the UV System Reactors that treat the water for Cryptosporidium.**

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Keith Tilley** at **254-729-5959**.

Posted /Delivered on: 3/26/25